



Test Report

No. VNHL2604010323HG

Date: May 15, 2026

Page 1 of 3

HTPLY VIETNAM COMPANY LIMITED

5TH FLOOR, NO. 564 NGUYEN VAN CU STREET, BO DE WARD, HANOI, VIETNAM

The following sample(s) was/were submitted and identified by the client as:

SGS Job No. : VNHL2604010323HG
 Sample Description : ANTI SLIP PLYWOOD
 Color : BLACK-BROWN
 Characteristic : FW 240GSM – EUCALYPUTS CORE – PHENOLIC GLUE
 Date of Production : APRIL 5TH 2026
 Manufacturer : HTPLY VIETNAM COMPANY LIMITED
 Country of Origin : VIETNAM
 Country of Destination : EUROPE, AFRICA, MIDLE EAST

As above information is provided and confirmed by the applicant. SGS is not liable to the accuracy, suitability, reliability or/and integrity of the information.

Sample Receiving Date : APRIL 28, 2026
 Final Confirmed Date : APRIL 28, 2026
 Testing Period : APRIL 28, 2026 TO MAY 15, 2026
 Test Requested : PLEASE REFER TO THE RESULT SUMMARY.
 Test Results : PLEASE REFER TO NEXT PAGE(S).
 Result Summary :

Test Requested	Conclusion
Shod Ramp Test	See Result

Signed for and on behalf of
SGS Vietnam LTD



Ung Thanh Van
Hardline SBU Manager

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en-vn/terms-and-conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.



Test Report

No. VNHL2604010323HG

Date: May 15, 2026

Page 2 of 3

Test Results:

Shod Ramp Test

Test Method: DIN EN 16165:2023-02 Determination of slip resistance of pedestrian surfaces - Methods of evaluation Annex B Shod ramp test

Test Condition:

Specimen: 1000mm×500mm, 1pc

Test surface: see photo

Test direction: long side direction

Test Result:

Test Item	Test Result	Slip Resistance Class
Shod Ramp Test	Ramp test value α_{shod} : 40°	R13

DIN EN 16165:2023-02 NB.2 Classification of the results by shod ramp test:

Test Result α_{shod}	Slip Resistance Class
$6^\circ \leq \alpha_{shod} \leq 10^\circ$	R9
$10^\circ < \alpha_{shod} \leq 19^\circ$	R10
$19^\circ < \alpha_{shod} \leq 27^\circ$	R11
$27^\circ < \alpha_{shod} \leq 35^\circ$	R12
$35^\circ < \alpha_{shod}$	R13

Sample Description:


A ANTI SLIP PLYWOOD

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en-vn/terms-and-conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

PHOTO OF SUBMITTED SAMPLE FOR TESTING



REPORT RESULTS REFER TO SUBMITTED SAMPLE(S) ONLY

*****End of Report*****

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en-vn/terms-and-conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.